

Robert Tipton

From: Church Hill Wastewater Plant <chwwtp@churchhilltn.gov>
Sent: Tuesday, April 18, 2017 9:47 AM
To: Robert Tipton
Subject: over flow

mr. robert tipton we had power outage sometime in the early morning of 04-16-2017. we had a recycled water line bust and spray water on a panel box in the belt press room. which tripped a breaker that shut the main power down. with the breaker being tripped we lost power to everything.

we are in the process of fixing the busted line and trying to find out why the breaker shut the power off to the plant. we lost 30 to 60 thousand gallons. we cleaned up and limed the area of the over flow. if you have any questions call me at 423-676-1531 thanks, greg linkous